



## EU Declaration of Conformity (DoC)

**Manufacturer's Name:** Automation Components Inc.

**Manufacturer's Address:** 2305 Pleasant View Rd  
Middleton, WI 53562 USA

**Date of Issue:** 12 April 2018

**Equipment:** Differential Pressure Transmitter A/MLP2 Series

**Model Numbers:** **A/MLP2-CCC-D-E-F-G-HH**  
A - Can be any letter indicted customer abbreviation for documentation' A = ACI  
CCCC - Indicated differential pressure range  
D - Units of pressure range (W = inches of Water Column; P = Pascals)  
E - Range type of unit (B = Bi-directional; U = Uni-directional)  
F - Unit accuracy (A =  $\pm 0.5\%$ ; B =  $\pm 0.25\%$ )  
G - Output signal (A = 4 to 20 mA; B = 0 to 5 VDC; C = 0 to 10 VDC)  
HH - NIST certification (0P = No NIST Certificate; 3P = 3 Point NIST Certificate;  
5P = 5 Point NIST certificate)

**Directives:** **RoHS Amendment 2015/863 to 2011/65/EU**  
**EMC 2014/30/EU**

**Standards:** **EN 61326-1:2013 / IEC 61326-1:2012**

**Tested By:** Interertek Testing Services NA, Inc.  
7250 Hudson Blvd., Suite 100  
Oakdale, MN 55128 USA

Automation Components Inc declares that to its knowledge, as of the date of this document, the products listed above conform to the requirements of the European Union's Restriction of Hazardous Substances (RoHS) Directive 2011/65/EU including Directive (EU) 2015/863, which amended RoHS to add 4 phthalates.

We hereby certify that the apparatus described above conforms to the essential requirements and provisions of the EMC Directives.

Signature:  Title: Quality Manager Date: 5/1/2024

***“Engineering a Better Sensor Solution”***